

## COMPRESSOR DATA SHEET

## In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive MODEL DATA - FOR COMPRESSED AIR Manufacturer: Ingersoll Rand 1 Model Number R90N-W145 4/28/2020 Date X Water-cooled 2 Air-cooled Type Screw # of Stages 1 115 3\* Full Load Operating Pressure b psig Drive Motor Nominal Rating 125 hp 5 Drive Motor Nominal Efficiency 95.4 percent 6 Fan Motor Nominal Rating (if applicable) 1.1 Fan Motor Nominal Efficiency 86.6 7 percent Specific Power Input Power (kW) Capacity (acfm) a,d (kW/100 acfm)<sup>d</sup> 115.0 606.0 18.98 104.6 554.4 18.87 95.3 503.1 18.94 8\* 86.6 453.2 19.11 403.3 19.39 70.1 353.1 19.85 305.0 62.5 20.49 0.0 Total Package Input Power at Zero Flow<sup>c, d</sup> 10 0.7 percent Isentropic Efficiency 35 Specific Power (kw/100ACFM) 50 11 10 200 300 500 700 Capacity (ACFM) Note: Graph is only a visual representation of the data in section 8

Consult CAGI website for a list of participants in the third party verificatio www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

Note: Y-axis scale 10 to 35, +5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity

- b. The operating pressure at which the Capacity (item 8) and Electrical Consumption (item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d Tolerance is specified in ISO 1217, Annex C, as shown in table below.

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m³/min	ft3 / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

Member

ROT 031.1

12/19 Rev 3

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.

<sup>\*</sup> For models that are tested in the CAGI Performance Verification Program, these are the items verified by the third party program administrator