

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

| | MODEL DATA - FO | OR COMPRESSED | AIR | | | | |
|----|--|---------------------------|----------------------------|--|----|---|-----|
| 1 | Manufacturer: Ingersoll Rand | | | | | | |
| | Model Number L300W-OF VFD Date | | Date: | 04/30/20 | | | |
| 2 | Air-cooled X Water-cooled Lubricated X Oil-Free | | Type: Screw # of Stages: 2 | | | | |
| | | | | | 3* | Full Load Operating Pressure ^b | 100 |
| 4 | Drive Motor Nominal Rating | 300 | hp | | | | |
| 5 | Drive Motor Nominal Efficiency | 96.2 | percent | | | | |
| 6 | Fan Motor Nominal Rating (if applicable) | 3 | hp | | | | |
| 7 | Fan Motor Nominal Efficiency | 89.5 | percent | | | | |
| | Input Power (kW) | Capacity (acfm) a,d | | cific Power /100 acfm) ^d | | | |
| | 253.6 | 1398 | 18.14 | | | | |
| | 238.3 | 1325 | 17.98 | | | | |
| 8* | 208.8 | 1175 | 17.77 | | | | |
| | 181.0 | 1022 | 17.71 | | | | |
| | 155.0 | 867 | 17.88 | | | | |
| | 146.8 | 815 | 18.02 | | | | |
| 9* | Total Package Input Power at Zero Flow ^{c, d} | 57.6 | kW | | | | |
| | 35.00 | | | | | | |
| | 25.00 Visual Parket (RW100 ACFN) 20.00 Specific Parket (RW100 ACFN) 20.00 | | | | | | |
| 10 | 15.00 | | | | | | |
| | 0 100 200 300 400 500 6 | 500 700 800 900 1000 1100 | 1200 1300 1400 1500 | 1600 1700 | | | |
| | Capacity (ACFM) | | | | | | |
| | Note: Graph is only a visual representation of the data in Section 8 Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35 X-Axis Scale, 0 to 25% over maximum capacity | | | | | | |

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

| Volume Flow Rate at specified conditions | | Volume Flow Rate | Specific Energy Consumption | No Load / Zero Flow Power |
|--|-----------------------|------------------|--------------------------------|------------------------------|
| m³/min | ft ³ / min | % | % | % |
| Below 0.5 | Below 17.6 | +/- 7 | +/- 8 | |
| 0.5 to 1.5 | 17.6 to 53 | +/- 6 | +/- 7 | +/- 10% |
| 1.5 to 15 | 53 to 529.7 | +/- 5 | +/- 6 | |
| Above 15 | Above 529.7 | +/- 4 | +/- 5 | |

ROT 031.2

PR3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.