	In A	ccordance with Feder	al Uniform Test Method for Co		ir Compressors	
		1	Rotary Compressor: Fixed S	*		1
	1	1 Manufacturer: Ingersoll Rand				
	1	_			2/20/2020	-
		Model Number: RS1		Date:	3/20/2020	-
	2	X Air-cooled	Water-cooled	Type:	Screw	
				# of Stages:	2	
	3*	Rated Capacity at Full	Load Operating Pressure <sup>a, e</sup>	975	acfm <sup>a, e</sup>	
	4*	Full Load Operating Pressure <sup>b</sup>		100	psig <sup>b</sup>	
5		Maximum Full Flow Operating Pressure <sup>c</sup> Drive Motor Nominal Rating		110 175	psig <sup>c</sup> hp	
	7	Drive Motor Nominal Efficiency		96.0%	percent	
	8	Fan Motor Nominal Rating (if applicable)		7.4	hp	
	9	Fan Motor Nominal Efficiency		91.0%	percent	
	10*	Total Package Input Power at Zero Flow <sup>e</sup>		61.1	kW <sup>e</sup>	
	11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>		153.9	$kW^d$	
	12*	Package Specific Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>		15.8	kW/100 cfm <sup>e</sup>	
	13	Isentropic Efficiency		84.3	Percent	
	* For models that are tested in the CAGI Performance Verification Program, these are the items verified by the third party program administrator					2
Consult CAGI website for a list of participants in the third party verification p NOTES: a. Measured at the discharge terminal point of the compresso cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (item 3) and for this data sheet. c. Maximum pressure attainable at full flow, usually the unlow maximum pressure attainable before capacity control begin d. Total package input power at other than reported operating e. Tolerance is specified in ISO 1217, Annex C, as shown in NOTE: The terms "power" and "energy" are synonymous for				l Consumption (item 11) were measured re setting for load/no load control or the equire additional power. vill vary with control strategy. ow.		
compressed A	α ods mistitute	NOTE: The terms "powe	er" and "energy" are synonymous for purposes of Volume Flow Rate		Specific Energy	No Load / Zero
			at specified conditions	Volume Flow Rate	Consumption	Flow Power
Ν	lember	$\frac{\text{m}^3/\text{min}}{\text{Below 0.5}}$	<u>ft<sup>3</sup> / min</u> Below 17.6	% +/- 7	%	%
		0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
OT 030.1		1.5 to 15	53 to 529.7	+/- 5	+/- 6	

Rev B

ECO 1341195