

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

	Rotary Compresso MODEL DATA	FOR COMPRESSED AIR		
1	Manufacturer: Ingersoll Rand	FOR COMINESSED AIR		
	Model Number: RS55n-A145	Da	ate: 2/19/2021	
2	X Air-cooled Water-cooled	Ту	/pe: Screw	
		# of Stag	ges: 1	
3*	Full Load Operating Pressure ^b	135	psig ^b	
4	Drive Motor Nominal Rating	74	hp	
5	Drive Motor Nominal Efficiency	96.0	96.0 percent	
6	Fan Motor Nominal Rating (if applicable)	1.5	hp	
7	Fan Motor Nominal Efficiency	84.1	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	68.1	344.7	19.74	
	62.1	313.0	19.83	
8*	56.0	280.5	19.96	
	50.0	248.1	20.16	
	43.9	214.8	20.46	
	34.2	160.6	21.30	
9*	Total Package Input Power at Zero Flow ^{c,d}	0	kW	
10	Isentropic Efficiency	76.3	percent	
11	35 30 25 20 15 10 0 50 100	1.50 200 250 300 Capacity (ACFM)	350 400	
	Note: Y-axis scale 10 to	a visual representation of the data in section 8 35, +5kW/100acfm increments if necessary above 35 ale, 0 to 25% over maximum capacity		

n, t ied by the t ird party prog www.cagi.org

Consult CAGI website for a list of participants in the third party verification program:

NOTES: a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.



b. The operating pressure at which the Capacity (item 8) and Electrical Consumption (item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.

d Tolerance is specified in ISO 1217, Annex C, as shown in table below. NOTE: The terms "power" and "energy" are synonymous for purposes of this document

Member	a	Volume Flow Rate at specified conditions		Specific Energy Consumption	No Load / Zero Flow Power			
	<u>m³/min</u>	ft3 / min	%	%	%			
	Below 0.5	Below 17.6	+/- 7	+/- 8				
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
ROT 030.1	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
	Above 15	Above 529.7	+/- 4	+/- 5				
12/19 Rev 3 This form was	developed by the Compressed Air and Gas In	oped by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.						

Rev B