

COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FO	OR COMPRESSED	AIR				
1	Manufacturer: Ingersoll Rand						
	Model Number E132ne-A145		Date: 04/15/21				
2	X Air-cooled Water-cooled	Туре:		Screw			
	Lubricated X Oil-Free	# of Stages:		2			
3*	Full Load Operating Pressure ^b	145	psig ^b				
4	Drive Motor Nominal Rating	2 x 88	hp				
5	Drive Motor Nominal Efficiency	97.0	percent				
6	Fan Motor Nominal Rating (if applicable)	2 x 3.75	hp				
7	Fan Motor Nominal Efficiency	90.5	percent				
	Input Power (kW)	Capacity (acfm) a,d	Specific Power (kW/100 acfm) ^d				
Ī	152.1	701	21.69				
	133.3	616	21.66				
8*	116.2	530	21.94				
Ī	100.7	444	22.70				
	85.9	358	24.01				
	72.1	272	26.53				
9*	Total Package Input Power at Zero Flow ^{c, d} 8.4 k						
10	35.00 30.00 25.00 20.00 15.00 10.00 50 100 150 200 250	300 350 400 450 500 550 Capacity (ACFM)		50 800 850			
	Note: Y-Axis Scale, 10 to 35,	isual representation of the data in \$\frac{8}{2}\$ + 5kW/100acfm increments if necess 0 to 25% over maximum capacity					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
- ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Flow Rate Consumption	
m ³ /min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.2

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.